



**Karnataka State Fire & Emergency Services**  
Office of the District Fire Officer  
Sarjapura-Road Fire Station, Bengaluru-560035.  
Ph : 080-25746166



**C.NO: 15/DFO/SRFS/FSCR/2024**

**dt: 20-03-2024**

**"Annexure--2"**  
**Educational Buildings**

To,  
The Authorized Signatory.  
M/s. Cambridge Public School,  
Somapur gate, hosahalli road,  
Sarjapura,  
Bangalore- 562125.

Sir,

Sub: Issue of **"Fire Safety Compliance report"** with respect to fire prevention, fighting and Evacuation measures maintained at "M/s. Cambridge Public School, somapur gate, hosahalli road, sarjapura, Bangalore-562125."

Ref: 1) DFO office FSR No: 15/DFO/SRFS/Bng/FSR/2024 ; Dt:-18-03-2024.

2) Your request letter dated: 14-03-2024.

3) FSO Inspection report no.15/FSO/SRFS/BNG/2024. Dt:-18/03/2024 & dt: 20-03-2024.

<<<<>>>>

With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises of "M/s. Cambridge Public School, somapur gate, hosahalli road, sarjapura, Bangalore-562125" with a Condition to fulfill the recommendations and compliance the same within 03 months,


With reference cited (2) above, the management of "M/s. Cambridge Public School" had requested for Issue of fire safety compliance report from our department. In this regard the Fire Station officer, Sarjapura-road Fire Station, Bangalore was inspected the building on dt: 15-03-2024 and submitted the report recommending to Issue the fire safety Compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is Issuing the **"Fire Safety Compliance Report"** to "M/s. Cambridge Public School, somapura gate, hosahalli road, Sarjapura, Bangalore-562125." Subject to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/ employees training within 03 months from the date of issue of this report.

**"This report is valid for one year from the date of issue of this report and is renewable without fail".**



Yours faithfully,

  
**DISTRICT FIRE OFFICER**  
Sarjapura Road Fire Station  
Bengaluru-560035





**Karnataka State Fire & Emergency Services**  
Office of the District Fire Officer  
Sarjapura-Road Fire Station, Bengaluru--560035.  
Ph : 080-25746166



**C.NO: 15/DFO/SRFS/FSR/2024**

**dt: 18-03-2024**

**"Annexure--2"**  
**Educational Buildings**

To,  
The Authorized Signatory.  
M/s. Cambridge Public School,  
Somapur gate, hosahalli road,  
Sarjapura, Bangalore- 562 125.

Sir,

Sub : Issue of "Fire safety Recommendation Certificate" to "M/s. Cambridge Public School, somapur gate, hosahalli road, sarjapura, Bangalore-562125."

Ref: 1) Your Request letter Date: 14/03/2024:


2) FSO Inspection report no.15/FSO/SRFS/BNG/2024. Dt: 18/03/2024.

><>>\*@\*<><<

With reference to the subject cited above, the premises "M/s. Cambridge Public School, somapur gate, hosahalli road, sarjapura, Bangalore-562125." was inspected by Fire Station officer Sarjapura-road fire station, Bangalore on **Dt:15-03-2024** for suggesting fire prevention, fire fighting & evacuation measures. The details are as follows:-

**A. Details of the building / premises :-**

01	Name and Address of the Applicant.	:	The Authorized Signatory. M/s. Cambridge Public School, Somapur gate, hosahalli road, Sarjapura, Bangalore- 562 125.
02	Name and Address of the premises.	:	M/s. Cambridge Public School, Somapur gate, hosahalli road, Sarjapura, Bangalore- 562 125.
03	Name and address of the Building owner	:	M/s. Cambridge Public School, Somapur gate, hosahalli road, Sarjapura, Bangalore- 562 125.
04	Number of buildings	:	One Building
05	Number of floors	:	Basement, Ground +2 upper floors.
06	<b><u>Floor-wise details of occupancy:- Block-A</u></b>		
	Basement	:	Store.
	Ground floor	:	10 Class Rooms 01 principal room, 01 staff room, 01 Chairman room.
	1 <sup>st</sup> floor	:	11 Class Rooms, 01 MD Room, 01 Canteen, 01 Staff room, 01 Library, 01 Computer lab.






	2 <sup>nd</sup> floor	:	08 Class Rooms, biology lab, chemistry lab, physics lab.
07	Height of the building	:	11.10 Mtrs.
08	Site area	:	5,924.14 Sq mtrs..
09.	Built-up area of each floor:-		
	Basement	:	161.55 Sq Mtrs.
	Ground floor	:	1,735.45 Sq. Mtrs.
	1 <sup>st</sup> floor	:	1,663.47 Sq. Mtrs.
	2 <sup>nd</sup> floor	:	1,268.40 Sq. Mtrs.
10.	Total built-up area	:	4,828.87 Sq. Mtrs.
11.	Surrounding properties:-		
	west (Front)	:	08.00 mtrs wide Hosahalli road.
	East (Rear)	:	Vacant land.
	South (side)	:	Vacant land.
	North (side)	:	Vacant land.
12.	<u>Set-back area available around the building :-</u>		
	west (Front)	:	Minimum 08.00 mtrs
	East (Rear)	:	06.00 mtrs
	South (side)	:	Minimum 04.00 mtrs
	North (side)	:	09.00 mtrs


**B.On inspection of this Industrial premises, the following fire prevention, fire-fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-**

Sl. No. (1)	Details (02 )	Existing (03 )		Recommendations (04 )
01.	Accessibility to the premises	The premise is accessible from 08.00 mtrs wide Hosahalli main road located on Eastern side the road is hardened to carry the Weight of 45.000 Kgs.		Adequate
02.	No. of entrances	01 entrances / exit		Complied
03.	Width of entry / exit	Entrance / exit of 06.20 mtrs has been provided.		Adequate
04.	Diesel generators.	01 generator of 65KVA capacity have been installed on the open space available on the Northern side. & connected to fire-fighting systems.		Complied
05.	No. of staircases available	Nos. of staircases	: 01	Complied
		Width of staircases	: 1.20mtrs	
		Width of treads	: 30 cm	
		Height of risers	: 15 cm	
		Nos. of riser per flight	: 12nos	
		Height of handrails	: 1.15 mtrs	
		Head room clearance	: 3.20 mtrs	
06.	No. lifts and capacity.	No lifts		--





07.	Fire extinguisher	08 No's. Of ABC fire extinguishers, each Of 06kgs capacity has been provided in The Building.	Complied
08.	First aid Hose reel hose.	Two Hose Reel Hose has been provided near the entrance gate of 19 mm size of adequate length to reach the farthest point of floor has been provided with shut off branch having a nozzle of 5mm size has been Provided.	Complied
09.	Terrace tank over respective tower terrace.	10,000 liters capacity of terrace tank has been provided.	Complied
10.	At the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup> .	Not -Complied	02nos of booster pumps has to be installed at the terrace level capable of delivering 450 liters of water per minute. (Further the system should be connected to an alternative source of power supply)
11.	Escape routes	Escape routes have been marked in which visibly to guide the students make to safer Places.	Complied
12	No Smoking Board	No smoking board has been displayed in English and kannada at inside the entry/exit of the each floor.	Complied
13	Fire Siren	A Fire siren has been installed inside the premises to inform all the inmates in case of a fire emergency and evacuate the area.	Complied
14	Nominate one fire no Nodal Officer	One Non-teaching staff has been nominated as fire nodal officer for the school premises.	Complied
15.	Fire order	A notice board has been displayed the Action to be taken by the school staffs in Case of an emergency with Telephone Numbers of <b>Sarjapura-Road Fire Station i.e. 25746166 &amp; 101</b> and telephone numbers of nearest Ambulance Service & Management Has been displayed.	Complied
16.	Fire fighting training	Not trained	At least 40% of teaching & non-teaching staff should be got trained in fire prevention and fire fighting evacuation measures at R.A. Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore-29






17. General Fire precaution measures :-
- A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
  - B. Accumulation of combustible waste in and around the premises should be avoided.
  - C. The exit ways shall be always kept clear without any obstruction.
  - D. Liquefied petroleum gas should be not stored in the building.
  - E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction.
  - F. During the class hours the class room doors shall not be locked from inside to outside.
  - G. As per Hon'ble Supreme Court order all teacher and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety day on April 14<sup>th</sup> of every year by conducting fire safety drills with co-ordinate with Fire Service Department.
  - H. This Fire Safety Recommendation is issued from the fire prevention, fire fighting and evacuation measures. Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing "Fire Safety Recommendation" to "M/s. Cambridge Public School, somapur gate, hosahalli road, sarjapura, Bangalore-562125." subject to condition and compliance of the above recommendations as shown in Column-4 of Part-B within 03 months and compliance from the undersigned.

**"This Fire Safety Recommendation is valid for Only One Year from the date of issue and it is renewable."**

*Yours faithfully,*



**DISTRICT FIRE OFFICER**  
**Sarjapura Road Fire Station**  
**Bengaluru-560035**